



Government Of West Bengal
Office Of The Divisional Fire Officer
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.:FSR/0125186210600106

Date: 17-10-2023

From:
Divisional Fire Officer
Darjeeling Division (Member Convenor)
West Bengal Fire & Emergency Services

To: RAIGANJ B.ED COLLEGE
KARNOJORA,RAIGANJ,UTTAR DINAJPUR

Sub: Issuance of Fire Safety Certificate for Existing construction of G+2 Educational Building under group of Educational in the name of RAIGANJ B.ED COLLEGE at the Premises no- Mouza- Karnojora,JL.NO- 157, KH.NO- KB 1/1, Plot no- 246 LR(NEW), 394,397,398 & 555 RS(OLD), KARNOJORA, P.S.- RAIGANJ, DIST . UTTAR DINAJPUR, WEST BENGAL, PIN – 733130,

This is in reference to your application no. 0125189230600056 dated 01-10-2023 regarding the Issuance of Fire Safety Certificate for Existing construction of G+2 Educational Building under group of Educational in the name of RAIGANJ B.ED COLLEGE at the Premises no- Mouza- Karnojora,JL.NO- 157, KH.NO- KB 1/1, Plot no- 246 LR(NEW), 394,397,398 & 555 RS(OLD), KARNOJORA, P.S.- RAIGANJ, DIST . UTTAR DINAJPUR, WEST BENGAL, PIN – 733130,

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all vulnerable of the

building.

6. Regular Mock fire Practices and evacuation drill should be conducted periodically by participation of all the occupants of the building and for this purpose a special crew should be formed.
7. A Crew of trained fire man should be maintained round the clock for the safety of the building.
8. Arrangement shall have to make for regular checking and testing of the fire fighting system in the building to keep the system in good working condition.
9. Periodical flashing of water in the Hydrant shall be made to maintain the efficiency of the above mentioned system.
10. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
11. The Fire Check Door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.
12. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
13. If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
15. Directional sign of escape route should be displayed prominently (Auto glow sign) at all conspicuous place of the building as per clause 5.5 of the N.B. code.
16. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
17. The Fire Safety Audit to be conducted at in a regular interval and to record in the Fire Prevention Maintenance register.
18. The Fire Safety Certificate is valid for three years and has to be renewed after three years from the date of issue of this letter As per Govt. of West Bengal Vide Notification No-629_L Dated-17/04/2018.
19. After three years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, on the basis of performance of all the Life & Fire Safety arrangements and installations of the building.

Signature Not Verified

Digitally Signed.
Name: DEBANU BASU
Date: 17-Oct-2023 17:42:34
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Darjeeling Division
West Bengal Fire & Emergency Services